



AUXILIUM COLLEGE (Autonomous)

(Accredited by NAAC with A+ Grade with a CGPA of 3.55 out of 4 in the 3rd cycle)
Gandhi Nagar, Vellore – 6.

7.1.2

PERMISSION DOCUMENT ELECTRICITY BOARD

GOVERNMENT OF TAMILNADU
ELECTRICAL INSPECTORATE

Web Site: www.tnei.tn.gov.in

Ph: 0416-2243588

From
The Electrical Inspector,
No: 19, 1st Floor, 10th East Main Road,
Gandhi Nagar East, Vellore - 632 006.

To
M/s. Auxilium College (Autonomous),
Gandhi Nagar,
Vellore - 632006.

Letter No. 579/EI/VLR/R-34 Solar/SC/2023, Dated 24.06.2023

Sir,

Sub: Electricity – 33 kW & 20 kW Roof Top Solar Power Plant Installations of voltage upto and inclusive of 650V at premises of M/s. **Auxilium College (Autonomous), Gandhi Nagar, Vellore - 632006** - Inspection under Regulation 34 of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2023 on 08.05.2023 - Permission to commission the equipment - Regarding.

- Ref: 1. Your letter No. Nil, Dated 03.04.2023 received on 11.04.2023 along with completion report and challan.
2. This office letter No. 579/EI/VLR/R32/2023, Dated. 08.05.2023.
3. Your letter No. Nil Dated 23.06.2023 received on 24.06.2023 along with rectification report

Permission are hereby accorded to commission the 33 kW & 20 kW Solar Power Plant Installation as given below inspected on 08.05.2023 under Regulation 34 of Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2023 subject to the following conditions.

Details of the Solar Power Plant Installation

Solar Panel - 1:

| | |
|-----------|--------------|
| Make: | Trinasolar |
| Capacity: | 320 WP/Panel |
| No: | 64 Nos |

Solar Inverter - 1:

| | |
|-----------|--------------------------------|
| Make: | Growatt |
| Sl. No.: | BCJ3BKA010 |
| Capacity: | 33 kW |
| Voltage: | 200V-1000V (DC)/230V-400V (AC) |

Solar Panel - 2:

| | |
|-----------|--------------|
| Make: | Zebra |
| Capacity: | 150 WP/Panel |
| No: | 120 Nos |

Solar Inverter - 1:

| | |
|-----------|--------------------------------|
| Make: | Growatt |
| Sl. No.: | CJJ4BLV03W |
| Capacity: | 20 kW |
| Voltage: | 160V-1000V (DC)/230V-400V (AC) |

SUBJECT TO THE FOLLOWING CONDITIONS:

1. The terms and conditions of the supplier/TANGEDCO Ltd should be complied with.
2. The permission granted now ceases to be valid when the Solar Power Plant is shifted from the above service connection.
3. It shall be the responsibility of the consumer to obtain any other necessary statutory Clearances/Approval from the appropriate authorities.
4. The date of commissioning of the Solar Power Plant should be intimated to this office, with a copy to the Superintending Engineer/TANGEDCO/Vellore, the Executive Engineer/TANGEDCO/O&M/Vellore and the Chief Electrical Inspector to Government, Chennai - 600032.
5. Tax on Consumption or Sale of Electricity using generator supply should be remitted monthly and returns sent to this office as per Tamil Nadu Tax on Consumption or Sale of Electricity Act, 2003.

V. Anand
ELECTRICAL INSPECTOR (FAC),
VELLORE.

Copy to: M/s. Malar Electricals, No. 25 & 26, Bye Pass Road, Veppur, Arcot - 632509, Ranipet District.

Copy to: The Executive Engineer/ TANGEDCO/O & M/Gandhi Nagar, Vellore - 6.

Copy to: The Superintending Engineer/TANGEDCO/Vellore Electricity Distribution Circle/ Gandhi Nagar, Vellore - 6.

Dr. Jagan Suresh - 2
PRINCIPAL
AUXILIUM COLLEGE (Autonomous)
Gandhi Nagar, Vellore - 632 006.
Vellore District, Tamil Nadu.